



HMRZ.EX27679 Gate Valves

[Page Bottom](#)

Gate Valves

[See General Information for Gate Valves](#)

AFCO (AMERICAN FIRE PRODUCTS COMPANY) CO

EX27679

500 DELAWARE AVE, STE 1 #1960
WILMINGTON, DE 19899 USA

Resilient Seated Gate Valves.

Pattern	Model	Size, in.	End Configuration	Rated Pressure, psig
*NRS	GV02-300-FF GV02-300-GG GV02-300-FG	2.5, 3, 4, 5, 6, 8, 10, 12	F by F G by G F by G	300
*NRS	GV02-300-FJ GV02-300-JJ	3, 4, 6, 8, 10, 12	F by M M by M	300
OS&Y	GV01-300-FF GV01-300-FG GV01-300-GG	2, 2.5, 3, 4, 5, 6, 8, 10, 12	F by F G by G F by G	300
OS&Y	GV01-300-FJ GV01-300-JJ	3, 4, 6, 8, 10, 12	F by M M by M	300
*NRS	GV02-250-FF GV02-250-GG GV02-250-FG	2.5, 3, 4, 5, 6, 8, 10, 12	F by F G by G F by G	250
*NRS	GV02-250-FJ GV02-250-JJ	3, 4, 6, 8, 10, 12	F by M M by M	250
OS&Y	GV01-250-FF GV01-250-FG GV01-250-GG	2, 2.5, 3, 4, 5, 6, 8, 10, 12	F by F G by G F by G	250
OS&Y	GV01-250-FJ GV01-250-JJ	3, 4, 6, 8, 10, 12	F by M M by M	250
*NRS	GV02-200-FF GV02-200-GG GV02-200-FG	2.5, 3, 4, 5, 6, 8, 10, 12	F by F G by G F by G	200
*NRS	GV02-200-FJ GV02-200-JJ	3, 4, 6, 8, 10, 12	F by M M by M	200
OS&Y	GV01-200-FF GV01-200-FG GV01-200-GG	2, 2.5, 3, 4, 5, 6, 8, 10, 12	F by F G by G F by G	200
OS&Y	GV01-200-FJ GV01-200-JJ	3, 4, 6, 8, 10, 12	F by M M by M	200

*NRS valve provided with a Post Indicator Flange

[Last Updated](#) on 2017-12-05

[Questions?](#)

[Print this page](#)

[Terms of Use](#)

[Page Top](#)

© 2018 UL LLC

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2018 UL LLC".

